



©2010 Arqiva
 All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted in any form or by any means (Electronic, Mechanical, Photocopying, Recording or otherwise), without the prior written consent of the Company.

NOTES

CONTRACTOR:- HF COMMS
 CONSULTANT:- HARLEQUIN GROUP
 RUTLAND HOUSE
 5 ALLEN ROAD
 LIVINGSTON
 EH54 6TQ
 ENGINEER:- R. NICOLL
 01506 462174
 r.nicoll@harlequin-group.com
 DRAWING MANAGER:- P.FERGUSON
 0141 4299361
 paul.ferguson@hocomms.com

PROJ No			
PROJ No			
PROJ No			
PROJ No			
PROJ No	158406		
.A	PLANNING ISSUE	30/01/15	HAR
ISS	REVISION	DATE	DRN APP



Crawley Court, Winchester, Hampshire, SO21 2QA
 Tel. 01962 823434, Fax. 01962 822378

SITE No 304319
 MIP_GLO2286
 DENFURLONG FARM
 ARABLE FIELDS ROAD
 CHEDWORTH, CHELTENHAM
 GLOUCESTERSHIRE
 GL54 4NQ

NGR SP 06288 10471
 OS GRID 406288 210471

TITLE
 SITE PLAN
 PROPOSED
 DCMS

SCALE 1:100
 DRAWN HAR 29/01/15

APPROVED

DRG No. Sheet 1 of 1 Rev
 304319-20-100-MD001 .A

FEINT DETAILS INDICATE LOCATIONS RESERVED FOR OTHER PROPOSALS WHICH MAY BE THE SUBJECT OF SEPARATE APPLICATIONS

NOTE: PROPOSED 10x10m TEMPORARY TRACKWAY WORKING AREA REQUIRED FOR CONSTRUCTION WORKS EXACT LOCATION T.B.C. AT PRESTART MEETING

SETTING OUT POINT OF COMPOUND
 E406988 N210471

ACCESS TRACK TO BE UPGRADED APPROX. 3.0m WIDE x 191m LONG TYPE 1 ACCESS TRACK c/w TURNING AREA

ACCESS TRACK TO BE RE-ROUTED AROUND PROPOSED COMPOUND

PROPOSED 3.0m WIDE DOUBLE ACCESS GATE

PROPOSED MBNL FREDO CABINET

PROPOSED MBNL SAMO CABINET

PROPOSED MBNL FCOA CABINET

PROPOSED 6.3m x 6.3m x 1.0m CONCRETE FOUNDATION WITH 50mm CHAMFER

PROPOSED GRAVEL FINISH WITHIN COMPOUND

PROPOSED CTIL 300mm WIDE SURFACE MOUNTED CABLE TRAY c/w COVER

PROPOSED 8.3 x 8.3m COMPOUND FORMED FROM 2.2m HIGH TIMBER CLOSE BOARDED FENCE

PROPOSED MBNL FEEDER BRACKETS FIXED TO TOWER LEG A

PROPOSED CTIL FEEDER BRACKETS FIXED TO TOWER LEG B

PROPOSED MBNL LINK A/C CABINET

PROPOSED DEDICATED EARTH PIT FOR INCOMING POWER

PROPOSED 2 USER METER CABINET ON PROPOSED CONCRETE BASE

PROPOSED INCOMING POWER UPVC DUCT (EATS SPEC12-24) DUCT SIZE TO BE CONFIRMED BY DNO

PROPOSED MBNL 450mm WIDE SURFACE MOUNTED CABLE TRAY c/w COVER

PROPOSED 30.0m HIGH HEAVY DUTY HUTCHINSON ENGINEERING LATTICE TOWER

PROPOSED CTIL TSC CABINET

PROPOSED CTIL RBS6102 CABINET

BARN

4-6m HIGH TREES

GRASS ACCESS TRACK

27m TO NORTH EAST CORNER OF BARN

GRASS VERGE

4-6m HIGH HEDGEROW

ACCESS TRACK

ARABLE FIELD

26° E.G.N.